

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER

Memo No : IND/WB/FES/20192020/69578

DATE: 04/12/2019

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :

TECHNO INDIA GROUP PUBLIC SCHOOL A UNIT OF THE ACADEMY OF
ENGINEERING AND MANAGEMENT TRUST
MANIPUR GHAT, PO AND PS NABADWIP, NADIA, PIN 741302
Nabadwip F.S., Nabadwip,
Nadia - 741302 .

Sub : Fire safety certificate for the existing G+II storied out building under group of Educational building in the name & style "TECHNO INDIA GROUP OF PUBLIC SCHOOL", A Unit of the Academy of Engineering & Management Trust, at the Premises no. Plot no. L.R. Khatiyon no. 15143, R.S. Dag no. 7516/13890, L.R. Dag no. 16813, Mouza – 20, Manipur Ghat Road, Nabadwip, Dist. – Nadia. Pin- 741302, West Bengal . The Site was inspected on 05/11/2019.

This is in reference to your Application No. IND/WB/FES/20192020/69578, dated 04/12/2019, regarding the Fire safety certificate for the existing G+II storied out building under group of Educational building in the name & style "TECHNO INDIA GROUP OF PUBLIC SCHOOL", A Unit of the Academy of Engineering & Management Trust, at the Premises no. Plot no. L.R. Khatiyon no. 15143, R.S. Dag no. 7516/13890, L.R. Dag no. 16813, Mouza – 20, Manipur Ghat Road, Nabadwip, Dist. – Nadia. Pin- 741302, West Bengal . The Site was inspected on 05/11/2019. .

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety



Vice Principal
TIGPS
Nabadwip-741302



Manager
TIGPS
Nabadwip-741302

1. All the Fire Safety Recommendations which were issued vide this department memo no. IND/WB/FES/20182019/17232 Dated – 23/07/2018 must be followed strictly at all time.
2. Driveway must to be free of anytime of obstruction for EASY movement of fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of building shall be made with low flame spread materiel confirming I.S.I. specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a close circuit T.V. system will have to be installed which will observe all the floor of the Building.
6. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of the Building.
7. The Employees and security staff shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire practice evacuation drill shall be performed periodically with participant of all the occupants of the building.
9. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.



Vice Principal
TIGPS
Nabadwip-741302



Manage
TIGPS
Nabadwip-741302

11. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.

12. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

13. Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.

14. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.

15. Transformer & switch Gear room (if applicable) shall be protected with CO₂ or D.C.P. Fire Extinguisher conforming I.S. Specification.

16. Storage of volatile flammable liquid shall be prohibited and the handling of such liquids shall restricted to science Laboratory only.

17. If gas use in the laboratory shall be provided with an approve out side gas shut-off valve conspicuously marked.

Būnśēn Būrnērs etc.

19.Fire Licence shall have to be obtained from the licence section of the department for proposed storing of highly combustible articles and procession with L.P.G., which come under purview of licence section as per Fire service Act-1950 (with up to date amendment).

20.This F.S.C. is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Performance of all the life & Fire Safety arrangements and installation of the Building.

21.Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by SUNIL
KUMAR MANDAL

Date: 2019.12.04 15:12:52 IST



Vice Principal
TIGPS
Nabadwip-741302



Manager
TIGPS
Nabadwip-741302