

Government Of West Bengal Office Of The Divisional Fire Officer, Nadia West Bengal Fire & Emergency Services Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo no.:IND/WB/FES/20192020/69578 Date: 06-04-2023

From:

Divisional Fire Officer, Nadia West Bengal Fire & Emergency Services

To: TECHNO INDIA GROUP PUBLIC SCHOOL A UNIT OF THE ACADEMY OF ENGINEERING AND MANAGEMENT TRUST

MANIPUR GHAT ROAD, NABADWIP, PIN 741302

Sub: Renewal of Fire Safety Certificate for Existing G+II storied building in the name & style of "Techno India Group Public School" comprising different unit under group of Educational Building at premises no. L.R Khatian No:15143,R.S Dag No:7516/13890,L.R Dag No:16813, Mouza:- 20, Monipur Ghat Road, P.O+P.S:Nabadwip, Dist:Nadia, 741302,W.B.

This is in reference to your application number 0125191231000025; dt: 02.03.2023 regarding the renewal of Fire Safety Certificate for existing G+II storied building in the name & style of "Techno India Group Public School" comprising different unit under group of Educational Building at premises no. L.R Khatian No:15143, R.S. Dag No:7516/13890, L.R. Dag No:16813, Mouza:20, Monipur Ghat Road, P.O+P.S: Nabadwip, Dist: Nadia, 741302, W.B.

The performance of the Fire Fighting system as in corporate in the aforesaid building were test and random found satisfactory working condition during inspection. On the basis of that this office is releasing renewal of "Fire Safety Certificate" for the aforesaid building.

Moreover to up-keep the Fire Safety measure the following safety measures need to be incorporated.

This is in reference to your application no. 0125191231000025 dated 02-03-2023 regarding the Renewal of Fire Safety Certificate for Existing G+II storied building in the name & style of "Techno India Group Public School" comprising different unit under group of Educational Building at premises no. L.R Khatian No:15143,R.S Dag No:7516/13890,L.R Dag No:16813, Mouza:- 20, Monipur Ghat Road, P.O+P.S:Nabadwip, Dist:Nadia, 741302,W.B.

This is in reference to your application number 0125191231000025; dt: 02.03.2023 regarding the renewal of Fire Safety Certificate for existing G+II storied building in the name & style of "Techno India Group Public School" comprising different unit under group of Educational Building at premises no. L.R Khatian No:15143,R.S Dag No:7516/13890,L.R Dag No:16813,Mouza:20,Monipur Ghat Road,P.O+P.S:Nabadwip,Dist:Nadia,741302,W.B.

The performance of the Fire Fighting system as in corporate in the aforesaid building were test and random found satisfactory working condition during inspection. On the basis of that this office is releasing renewal of "Fire Safety Certificate" for the aforesaid building.

Moreover to up-keep the Fire Safety measure the following safety measures need to be incorporated.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.Good housekeeping shall always be maintained.
- 2.Necessary precautions shall always be taken during storing, processing, handling, using raw & finished Jute and careful about any fiction in the machinery during processing of jute to avoid any incident.
- 3.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- 4.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 5. The Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in the them, Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March every years.
- 6.A fire control room including a close circuit T.V system will have to be installed which observe all floor of the building podium shall be incorporate with the system.
- 7. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at the venerable of the building.
- 8. The employees and security staff shall be conversant with installed Fire fighting equipments of the building and to operate in the event of Fire & testing.
- 9.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupancy of the building.
- 10.A crew of trained Fire man under experience officer shall be maintained round the clock for Fire Safety of the building.
- 11.Arrangement shall have to be made for regular checking, testing and maintains of all the Fire Fighting installation in the building to kept them in perfectly good working condition at all the time.
- 12. The inertial finish decoration of building shall be made with low flame spread material confirming of I.S specification.
- 13.One(01) number Jockey pump shall be provided within 02(two) months issue of R.F.S.C.
- 14. The First Aid Fire Fighting arrangement in the style of placing suitable Fire Extinguisher, Fire buckets etc shall be provided where not provided.
- 15.Periodical flashing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mention system.
- 16. The Fire Safety audit to be conducted a regular interval and the be record in the Fire Prevention maintenance register.
- 17. This Renewal Fire Safety Certificate is valid for three years and have to be renewed every three years interval from the date of issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the performance of all the life & Fire Safety arrangement and installation of the building.
- 18. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office this Fire Safety Certificate will be treated cancelled automatically.

Divisional Fire Officer, Nadia West Bengal Fire & Emergency Services

Neno No. INDINBIFES 2019 20169518

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191231000025.